

Laboratory approved by the Ministry for the Interior
JO of February 10, 2007

OFFICIAL REPORT OF CLASSIFICATION OF FIRE PERFORMANCE
OF A MATERIAL ENVISAGED IN ARTICLE 5

DECREE OF November 21, 2002

N° **CM - 10 - 026/B/1**
at 3 annexes.

Page 1

Valid 5 years as from mercredi 7 avril 2010

Material presents by : **A. BERGER GmbH&Co KG Textilwarenfabrik**

Kuhleshütte 84

47809 KREFELD

Trade mark: **ARCHITEX PES DECOR FR WHITE**

Summary description

Type de support knitted fabric

Composition 100% polyester FR (Flamme retardant)

Masse surfacique ~245 g/m²

Epaisseur ~0,34 mm

Coloris white

Traitements subis two side PU-coating

Nature of the test : Essai au brûleur électrique

Essai de persistance de flamme

Essai de gouttes

Classification : **M1**

Durability of the classification (Article 5 de l'annexe 2) : Non limitée a priori

Usual term Intérieur (à l'abri des intempéries)

Condition of enteten Selon préconisations du client

Taking into account the criteria resulting from the tests annexed described in the test report N° 367100179

This official report attests only characteristics of the sample submitted for testing and does not préjuge similar characteristics of products. It thus does not constitute a certification of products within the meaning of the L.113-27 article of the code of the consumption and the law of June 3rd, 1994.

NOTE: The integral reproductions and by photocopy of this official report of classification are only authorized on the official report unit of classification and report of annexed test.


“Valid for any application for which the product is not subjected to mark (CELOGI 2006)”
“Not legally acceptable for any use under the pretence of the article AM 18 (Decree of March 08, 2006)”

In charge of the test

Paris, le lundi 19 avril 2010

Only the french version remains valide


Clotilde ETTEMVRE



Siège social
10 Avenue de Saint-Mandé

75012 Paris

Tél + 33 (0)1 40 19 49 19 / Fax + 33 (0)1 43 40 85 65

www.afcoel.fr / www.ctba.fr

Siret 775 680 903 00017

APE 731Z

Code TVA CEE : FR 14 775 680 903

Institut technologique FCBA : Forêt, Cellulose, Bois - construction, Ameublement